

TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT
NO OBJECTION CERTIFICATE

NOC No.: 41 /IV/2025
DATE : 10.09.2025

Cuddalore Fire and Rescue Service Station.

Sub: Fire and rescue service department – Cuddalore
Fire and Rescue Service Station for purpose of
No objection certificate – Reg.

Ref : (1) G.O. No.122. School Edu (2) Dept, Date : 14.09.2004.
(2) G.O. No.123 School Edu (2) Dept, Date : 14.09.2004.
(3) Requisition letter from The Principal,
CK School of Progressive Education (CBSE), Cuddalore – 3.

No objection Certificate is hereby granted under section 13 of the Tamil Nadu Fire Service Act, 1985 for constructed of School Building at T.S.No.324/2, 324/5A, 324/5B, Jayaram Nagar, Sellankuppam, Cuddalore- 607 003. The building and premises comprises of G+2 owned / Occupied by **CK School of Progressive Education (CBSE)** have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 10.09.2025 in the presence of Principal and that the school upto classes XII is granted No objection certificate for a period of three year from 24.07.2025 to 23.07.2028 subject to the conditions stated below.

THE ABOVE PREMISES INSPECTED BY ASSISTANT DISTRICT OFFICER FIRE & RESCUE SERVICES, G.ARUMUGAM ON 10.09.2025


CONDITIONS

1. This License is valid for three year month from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a) Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code-2005.
 - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
 - d) Periodical maintenance and care should be taken to maintain all fire protection equipments.

- e) Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Cuddalore.
- f) The classrooms should always be in the ground floor upto 3rd standards.
- g) The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
- h) The classroom doors/ windows shall always open outwards.
- i) The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
- j) A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
- k) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.
- L) All the floors should be provided Down comer with Hose Reel System.

(If the Condition of not fulfilled within 3 months the license will be automatically cancelled).

If here is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.



[Signature]
**Asst. District Officer,
Fire & Rescue Services,
Cuddalore Station.**

To:
The Principal,
CK School of Progressive Education (CBSE),
T.S.No.324/2, 324/5A, 324/5B, Jayaram Nagar,
Sellankuppam, Cuddalore- 607 003.

[Signature]

**K. SUDHA, M.Sc.,B.Ed.,
PRINCIPAL
CK SCHOOL OF PROGRESSIVE EDUCATION
CBSE Affiliation No: 1931286
Jayaram Nagar, Chellankuppam,
Cuddalore - 607 003. Tamil Nadu**

[Signature]
**UDHAVALLI RANGANATHAN,
CORRESPONDENT,
CK SCHOOL OF PROGRESSIVE EDUCATION
Jayaram Nagar, Chellankuppam,
Cuddalore Dist., Pin: 607 003 Tamil Nadu**